


**ADDENDUM NO. 2**

**Constructing, Drilling and Testing of Wixson Well 2  
January 25, 2021**

1. Within the first paragraph of the Introduction on page 2 of the bid set, the referenced standard specifications are:
  - a. Standard Specifications for Road, Bridge, and Municipal Construction 2021, M 41-10.
2. Please delete the first sentence under Amendments to the Standard Specifications on page 2 of the bid set as shown below. The APWA Supplement is no longer relevant to the current version of the Standard Specifications.
  - a. ~~The APWA Supplement to division one for Municipal Public Works Construction are hereby adopted.~~
3. We estimate the time for geophysical logging of the borehole to be 8 hours.
4. We estimate the time for providing a well screen assembly design after the total depth has been reached to be approximately 2 days.
5. Please add to the end of first paragraph under section of FAILURE TO COMPLETE WORK ON TIME-LIQUIDATED DAMAGES.
  - a. SWD has established liquidated damages to be \$1,000 per day.
6. Please replace the paragraph 3.1 on page of the Scope of Work on page 16 of the bid set with the following;
  - a. Drilling Machine. Drilling shall be accomplished by fluid-rotary methods only with a rig capable of drilling a 16-inch nominal hole to a depth of 1,000 feet. The minimum mud-pump size shall be capable of producing an up-hole velocity sufficient to maintain circulation, transport cuttings to the surface without partitioning, and have reasonable lag times of less than approximately 30 minutes from the anticipated total depth 1,000 feet in a 20-inch-diameter boring. All appurtenant equipment including, but not limited to, sand cyclones, shale shakers, bailers, casing jacks, grout pumps and tremie tubes are to be considered as part of the rig, available to the project as needed, and delivered to the site as a function of job mobilization.

Silverdale Water District

  
\_\_\_\_\_  
Morgan Johnson, General Manager

Received by:

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name Printed

\_\_\_\_\_  
Date